



#### 56 LESLIE HOUGH WAY · SALFORD · GREATER MANCHESTER · M6 6AJ · UNITED KINGDOM

Email: testing@inspec-international.com

Website: www.inspec-international.com

Tel: +44 (0)16 1737 0699

Fax: +44 (0)16 1736 0101

# **Test Report AS/NZS 1716 : 2012**

# Respiratory protective devices

Report no:

1.15.09.65

Client:

**INSPEC Certification Services** 

56 Leslie Hough Way

Salford

Greater Manchester

M6 6AJ

**United Kingdom** 

(on behalf of):

Welding Guns of Australia Pty Ltd.

Client order:

TT15/0059

Order(s) received:

24 March to 30 September 2015

Model(s):

P1004

Date(s) of tests:

22 April to 30 September 2015

Signed:

Peter Threlfall, Laboratory Manager

P. Infall.

Issued: 6 October 2015
Page 1 of 20

#### **Conditions**

This report may be reproduced and distributed to your clients, provided that it is reproduced and distributed in full.

Unless stated otherwise, the testing is accredited under the laboratory's ISO/IEC 17025 accreditation issued by ANSI-ASQ National Accreditation Board. Refer to certificate and scope of accreditation AT-1933.

Tests marked 

are not included in our ISO/IEC 17025 accreditation.

Opinions, comments and interpretations expressed in this report are shown in italics.

Copies of INSPEC interpretations referenced in this report are available upon request.

Specimens will be disposed of four weeks from the date of this report, unless otherwise instructed.

This report has been provided in accordance with our standard Terms of Business, which can be viewed at, and printed from:

http://inspec-international.com/ToB.pdf

If you have difficulty accessing the Terms of Business, you may contact us for a copy.

# Summary of assessment\* Submission One

Clause	Requirement		sment Key)
		Submission One	Submission Two
2.1.1	GENERAL REQUIREMENTS - assembled respirators	Ltd	
2.1.2	Materials	Ltd	
2.1.3	Filters	Pass	
2.1.4	Shelf life	NAs	
2.1.5	Combined protective equipment		
2.1.6	Noise level	Pass	
2.1.7	Protection against explosion		
2.1.8	Avoidance of frictional sparks		
2.1.9	Protection from flame impingement		
2.2.1	FACIAL FIT - General	Pass	
2.2.2	Assessment	Pass	
2.3	BREATHING AND CONNECTING TUBE	Ltd	
3.1.1	DESIGN REQUIREMENTS - General	Pass	
3.1.2	Exhalation valve assembly	NAp	
3.1.3	Mouthpiece and nose clip		
3.1.4	Nose clip		
3.2.1	PERFORMANCE REQUIREMENTS - Facial fit	Pass	
3.2.2	Accumulated carbon dioxide	Pass	
3.2.3	Positive pressure screening test	Pass	
3.2.4	Exhalation valve	NAp	
3.2.5	Exhalation resistance - Air filtering respirators	Pass	
3.2.6	Security of attachments	Pass	
4.1	PARTICLE FILTERS - DESIGN AND CONSTRUCTION	Pass	
4.3.1	PERFORMANCE REQUIREMENTS - General	Pass	
4.3.2	Simulated rough usage	Pass	
4.3.5	Test of filtering efficiency	Pass	
4.3.6	Filters used in series	NAp	
5.1	GAS FILTERS - DESIGN AND CONSTRUCTION		
5.4.1	PERFORMANCE REQUIREMENTS - General		
5.4.2	Particulate filtration efficiency		

Clause	Requirement		sment Key)
		Submission One	Submission Two
5.4.3	Simulated rough usage		
5.4.5	Filter capacity		
5.4.7	Desorption		
6.1	PAPR - DESIGN AND CONSTRUCTION	Fail	
6.3.1	Battery	Pass	
6.3.2	Particulate filters	Pass	
6.3.3	Gas filters	NAp	
6.3.4	Combined filters	NAp	
7	ESCAPE RESPIRATORS - FILTRATION TYPE		
8	AIR-HOSE AND AIR-LINE RESPIRATORS		
9	COMPRESSED AIR SCBA		
10	COMPRESSED OXYGEN SCBA		
11	CHEMICAL OXYGEN SELF-RESCUERS		
12.1	Marking	Fail	Ltd
12.2	Instructions for use	Fail	Pass

## <u>Key</u>

	Shading shows the clauses requested. Any other clauses were not requested.		
Pass	Requirement satisfied.		
Ltd	Testing requested was insufficient completely to verify compliance with the clause. Refer to the "Result details" section for more information.		
Fail	Requirement not satisfied. Refer to the "Result details" section for more information.		
NAs	Assessment not carried out.		
NAp	Requirement not applicable.		
NT	Requested but not tested due to early termination following failure.		

<sup>\*</sup> Assessment relates only to those specimens which were tested and are the subject of this report.

## Product characteristics

Property	Characteristic	
Model	P1004	
Device type	Powered air-purifying respirator	
Rated duration (hours)	Level 1 = 8, Level 2 = 6, Level 3 = 4	
Power source Battery		
Recommended minimum flow	165	
Recommended cleaning method	Soft cloth	

### **Submission details**

Product	Quantity	Date Received	INSPEC specimen no. (1C0155 +)
	Submission C	ne	
Helmet	2		(1C0037+) 101 and 102
Breathing hose	2		(1C0037+) 301 and 302
Charger	2	14 January 2015	(1C0037+) 501 and 502
Flow checker	2		(1C0037+) 601 and 602
Particle filter	15		(1C0037+) 701 to 715
Blower	2	00 Mayab 0045	201 and 202
Battery	2	23 March 2015	401 and 402
	Submission T	<b>v</b> o <sup>-1</sup>	
Helmet	1		103
Breathing hose	1		303
Blower	1		203
Battery	1	29 September   2015	403
Charger	1		503
Flow checker	1		603
Particle filter	1		716

<sup>&</sup>lt;sup>-1</sup> Second submission submitted for clause 12 assessment only, no other clauses assessed.

#### **Device details**

Device	001	002	
Components	Specimen Number		
Helmet	(1C0037+) 101	(1C0037+) 102	
Blower	201	202	
Blower unit cover	(1C0037+) 211	(1C0037+) 212	
Spark arrestor	(1C0037+) 221	(1C0037+) 222	
Pre-filter	(1C0037+) 231	(1C0037+) 232	
Belt and harness	(1C0037+) 241	(1C0037+) 242	
Breathing hose	(1C0037+) 301	(1C0037+) 302	
Breathing hose cover	(1C0037+) 311	(1C0037+) 312	
Battery	401	402	
Charger	(1C0037+) 501	(1C0037+) 502	
Flow checker	(1C0037+) 601	(1C0037+) 602	
Particle filter	(1C0037+) 701	(1C0037+) 702	

#### **Procedures**

The specimens detailed within the submissions above were used for the tests covered by this report.

Testing was performed in accordance with AS/NZS 1716 : 2012 unless otherwise specified below. Reference should be made to the standard when reading this report.

Unless stated otherwise, specimens were tested in the condition as received by INSPEC.

- **2.1.6** Testing was undertaken to the method given in Appendix A.
- 2.2.1 Test subjects were selected according to the requirements of Appendix B, as detailed in section 2.2.2.
- 2.2.2 Testing was conducted to the method given in Appendix D, using sodium chloride aerosol.
- 3.2.2 Testing was conducted to the method given in Appendix E, paragraph E5.3.
- 3.2.3 Testing was conducted to the method given in Appendix E, paragraph E5.5.
- **3.2.5** Testing was conducted to the method given in Appendix G.
- **4.3.2** Pre-conditioning was conducted to the method given in Appendix H4.
- **6.3.1** Testing was conducted in accordance with Appendix Q and in conjunction with 3.2.3.
- 6.3.2 Testing was conducted in accordance with Appendix I and in conjunction with 4.3.5.
- 6.3.3 Testing was conducted in accordance with Appendix Q and in conjunction with 5.4.5.

# Result details Submission One

#### 2 DESIGN AND CONSTRUCTION OF ASSEMBLED RESPIRATORS

#### 2.1 GENERAL REQUIREMENTS

#### 2.1.1 Assembled respirators

The apparatus was constructed from components which proved durable during the laboratory tests undertaken.

**Pass** 

The conditions under normal use which might cause damage or excessive wear to the apparatus could not be determined in laboratory tests. Manufacturer to certify regarding normal use conditions.

NAs

The specimens were free of sharp edges and irregularities which may cause a potential hazard to a wearer.

**Pass** 

#### 2.1.2 Materials

The devices were able to withstand the laboratory testing for the tests undertaken.

The conditions and environments likely to be encountered during storage and use could not be determined in laboratory tests. Manufacturer to certify regarding these conditions and environments.

NAs

**Pass** 

No materials in contact with the skin of wearers during inward leakage testing showed evidence of staining, were soft and pliable and did not cause skin irritation.

Pass

The effects of material released by the filter medium could not be assessed. Manufacturer to certify regarding material release.

NAs

#### 2.1.3 Filters

The filters could be readily replaced without the use of special tools.

Pass

The filters were designed and marked to prevent incorrect assembly.

Pass NAp

The filters cannot be attached to a facepiece, fitting of twin filters is not applicable.

The filter was a particulate filter only, assessment of its position with a gas filter is

not required.

NAp

The filters were not fitted directly to the facepiece; assessment of mass is not required.

NAp

#### 2.1.4 Shelf life

No information regarding shelf life was provided.

NAs

#### 2.1.6 Noise level

Device	Test subject	Noise level dB(A)	
001	TF	75.4	
Maximum	80	1	

Pass

#### 2.2 FACIAL FIT

#### 2.2.1 General

None of the test subjects reported undue discomfort during inward leakage testing.

Pass

#### 2.2.2 Assessment

#### Leakage (%)

Subject	Device	Walk	Head side/side	Head up/down	Talk	Walk	Mean
KDS	101	0.019	0.018	0.016	0.015	0.014	0.016
ВН	102	0.005	0.007	0.004	0.027	0.004	0.009
INH	101	0.010	0.010	0.010	0.173	0.010	0.042
ED	102	0.003	0.003	0.003	0.006	0.002	0.004
PBU	101	0.007	0.007	0.007	0.007	0.007	0.007
JAD	102	0.002	0.002	0.002	0.062	0.001	0.014
RAR	101	0.006	0.006	0.009	0.334	0.116	0.094
KRB	102	0.002	0.002	0.001	0.002	0.001	0.001
AG	101	0.006	0.011	0.018	0.293	0.038	0.073
NRA	102	0.001	0.001	0.001	0.029	0.001	0.007
Maximum permitted				1.0	•		

All 50 individual exercise results were not greater than 1%.

All 10 mean results were not greater than 1%.

Pass Pass

#### Subject facial dimensions

Subject	Group	Face width	Face length
KDS	Α	128	102
вн	В	139	120
INH	С	153	125
ED	В	138	114
PBU	В	141	116
JAD	В	136	113
RAR	В	138	116
KRB	Α	130	108
AG	С	148	133
NRA	В	138	114

**Pass** 

**Pass** 

NAs

**Pass** 

**Pass** 

**Pass** 

NAp

NAp

**Pass** 

NAp

NAp

NAp

NAp

#### 2.3 BREATHING AND CONNECTING TUBE

The breathing tube fitted was assessed as given below.

- (a) Was flexible and permitted free head movement without interference to the facial seal
- (b) Did not restrict or close off the air supply as a result of bodily movement.
- (c) Assessment of temperature effects was not carried out.

#### 3. FACEPIECES HEAD COVERINGS AND HARNESSES

#### 3.1 DESIGN REQUIREMENTS

#### 3.1.1 General

The following assessments against this clause were made.

- (a) Assessment of fit on a range of facial contours is detailed in 2.2.2.
- (b) The device was held on the wearer's head using an adjustable ratchet.
- (c) Component parts requiring service were readily detached but secured against accidental disconnection.
- (d) The device was not designated as suitable for abrasive blasting.
- (e) The device did not incorporate a bib or hood.

No adverse comments were made by test subjects regarding interference with speech or vision during inward leakage testing.

The device was not a full facemask, assessment of visor misting and the fitting of spectacles is not applicable.

The device was not a full face mask; assessment of use with special spectacles was not required.

The device was not a full face mask; assessment of speech transmission was not required.

The device was not intended for use solely for escape, the requirements regarding a mouthpiece do not apply.

#### 3.1.2 Exhalation valve assembly

The device was not fitted with an exhalation valve.

NAp

#### 3.2 PERFORMANCE REQUIREMENTS

#### 3.2.1 Facial fit

Assessment of facial fit was determined as given in 2.2.2.

**Pass** 

#### 3.2.2 Accumulated carbon dioxide

Testing was conducted at the manufacturer's minimum specified flow, as given below.

**Pass** 

Device	Accumulated carbon dioxide (%)
001	0.70
002	0.73
Maximum permitted	1.0

#### 3.2.3 Positive pressure screening test

See clause 6.3.1.

Pass

#### 3.2.4 Exhalation valve

#### 3.2.4.1 General

The device did not incorporate an exhalation valve.

NAp

#### 3.2.5 Exhalation resistance - Air filtering respirators

**Pass** 

Device	Level	Exhalation resistance (Pa)
7	1	17
001	2	20
	3	24
	1	22
002	2	25
	3	32
Maximum	permitted	200

#### 3.2.6 Security of attachments

Devices 001 and 001 were tested.

The fittings directly attached to the apparatus withstood an axial tensile force of 50N for 10s.

**Pass** 

Simulated work tests were not required; assessment of attachments was not needed.

NAp

All of the attachments and components remained intact during facial fit tests.

**Pass** 

#### 4. PARTICULATE FILTER RESPIRATORS

#### 4.1 DESIGN AND CONSTRUCTION

The apparatus offered protection against particulates as defined in this section.

Assessment of the efficiency of the design to pass inhaled air through the filter is given in section 2.2.2.

The additional requirements of appropriate clauses are given in 6.1.

#### 4.2 CLASSIFICATION AND COMPONENTS

#### 4.2.1 Classes

The filters were designated as class P2, as defined in section (b).

#### 4.2.2 Components

In addition to the filters listed in 4.2.1, the component parts of the apparatus are listed in 6.2.

#### 4.3 PERFORMANCE REQUIREMENTS

#### 4.3.1 General

Evaluation of the performance requirements is as detailed below. Testing was conducted in the listed sequence.

#### 4.3.2 Simulated rough usage

Specimens (1C0037+) 711 to 715 were tested subjected to the conditioning given in Appendix H4.

None of the specimens tested suffered visible deterioration.

Pass

Pass

#### 4.3.5 Test of filter efficiency

See 6.3.2 for additional information

#### 4.3.6 Filters used in series

The filter is a particle filter only.

NAp

Ltd

**Pass** 

**Pass** 

NAp

Fail

**Pass** 

**Pass** 

NAp

**Pass** 

**Pass** 

#### 6 POWERED AIR-PURIFYING REPIRATORS

#### 6.1 DESIGN AND CONSTRUCTION

The respirator provided protection as given in this report.

The appropriate requirements of section 2 were met for the limited tests undertaken.

The appropriate requirements of section 3 were met.

The appropriate requirements of section 4 were met.

The filter did not incorporate a gas filter element; conformance to section 5 was not required.

The appropriate requirements of section 12 were not met.

(a) The respirator provided filtered air for not less than the defined period.

(b) The respirator provided a positive air pressure in the wearer's breathing zone so as to minimise the entry of unfiltered air.

(c) The respirator was not fitted with a facepiece, assessment of the seal was not appropriate.

(d) The component parts of the respirator could be readily detached for maintenance and cleaning but were secure against accidental disconnection.

The respirator incorporated an integral power supply which was easily portable on the wearer's person.

The power supply included a separate battery pack.

#### 6.2 COMPONENTS

#### 6.2.1 Facepiece type

The apparatus was of the hood or helmet type, see 6.2.2 for component details.

#### 6.2.2 Hood or helmet type

The apparatus consisted of the following components.

- (a) A head covering in the form of a helmet.
- (b) A means of diffusing the air entering the head covering.
- (c) A powered filtering unit, which in turn comprised of:
  - (i) a filter;
  - (ii) a filter holder;
  - (iii) a blower unit;
  - (iv) a battery pack;
- (e) A flexible breathing tube.
- (g) A waist belt and body harness.

#### 6.3 PERFORMANCE REQUIREMENTS

#### 6.3.1 Battery

The battery provided was of the non-spillable type.

The battery was sealed; a venting device was not required.

Pass NAp

Device	Level	Determined initial flow (I/min)	Flow at design duration (I/min)	Pressure in head covering (Pa)
	1	190	192	2.5
001	2	216	220	7.0
	3	261	257	5.5
	1	199	205	4.0
002	2	225	230	4.5
	3	262	265	9.5
Minimum re	equirement	1	65	2.5

Pass Pass Pass Pass Pass

Manufacturer's stated design duration:

Level 1= 8 hours

Level 2= 6 hours

Level 3= 4 hours

A means was provided to enable the wearer to determine if air flow was sufficient to maintain positive pressure, as detailed below.

**Pass** 

A flow check device was provided.

#### 6.3.2 Particulate filters

**Pass** 

Specimen	Pre-conditioning	Penetration (%)
(1C0037+) 711	4.3.2	0.70
(1C0037+) 712		0.44
(1C0037+) 713		0.40
Maximum permitted		6.0

Filter efficiency was measured using air flow of 260 l/min.

No additional marking was provided.

NAs

12	MARKING AND INSTRUCTIONS		
12.1	MARKING		
12.1.1	General		
	Assessment of the product and packaging marking is given below.		
12.1.2	Marking of face pieces and head coverings		
12.1.2.1	Marking of equipment		
	The marking of the head covering was assessed as follows.		
	The marking on the head covering was clear.	Pass	
	The marking on the head covering was indelible.	Pass	
(a)	The manufacturer's name or trademark was not marked.	Fai	
(b)	Size marking was not required as only a single size was offered.	NAp	
12.1.2.2	Additional marking		
	The packaging or label was not marked.	Fail	
12.1.3	Particulate filters		
12.1.3.1	Marking of equipment		
	Each filter was clearly marked with the information detailed below.	Pass	
(a)	The manufacturer's name or trade mark was given.	Pass	
(b)	The filter classification was given.	Pass	
	The white colour code was present.	Pass	
(c)	The filters were marked with "PAPR" but this was not as a prefix to the classification.	NAs	
12.1.3.2	Additional marking		

#### 12.2 INSTRUCTIONS FOR USE

The information supplied by the manufacturer has been assessed as detailed below, with reference only to the relevant requirements of the Standard.

INSPEC Testing Services has not assessed these instructions with respect to claims made by the manufacturer outside of the requirements of the Standard, and therefore accepts no responsibility for the legitimacy of any such claims.

#### 12.2.1 General

Instructions were supplied for evaluation as a draft copy. Manufacturer to confirm regarding supply of instructions to users.

NAs

Instructions supplied were in English.

Pass

The supplied instructions referenced the required information as listed below.

(a) Limited storage life of unopened filters was not given.

Fail

(b) Limited storage life of installed filters was not given.

Fail

#### 12.2.2 Instructions for use, maintenance and storage

Instructions were not supplied with the smallest package.

Fail

The instructions supplied were assessed as follows.

(b) Limitations on use were defined.

Pass

(c) Information on compatible filter types was given.

Pass

(d) Instructions on correct assembly of parts were given.

Pass

(e) Instructions of fitting were given, but no instructions regarding checking the correct facial fit were provided.

Fail Pass

(f) Instructions for decontamination were given.

Pass

Instructions for maintenance were given.

Pass

Instructions for storage were given.

Instructions for washing were given.

Pass

Instructions for periodic testing were given.

Pass

(g) Information on air pressure was not required.

NAp

(h) No information on additional or operational characteristics was given.

NAp

#### 12.2.3 Additional requirements for powered air-purifying respirators

The additional information did not accompany each device; an example copy only was supplied for assessment.

(d) The range of temperatures under which the equipment was tested was not given.

Fail

(a) A procedure for charging the battery was included.

Pass

(b) A procedure for checking the air flow was included.

Pass Pass

(c) A procedure for changing the filters was included.

Fail

(e) The operating range of temperatures was given.

Pass

#### 12.3 ADDITIONAL MARKING

The device was a rigid or semi-rigid head covering; was not marked in accordance with AS/NZS 1801 but the required warning was not given.

Fail

# Result details Submission Two

12	MARKING AND INSTRUCTIONS	
12.1	MARKING	
12.1.1	General	
	Assessment of the product and packaging marking is given below.	
12.1.2	Marking of face pieces and head coverings	
12.1.2.1	Marking of equipment	
	The marking of the head covering was assessed as follows.	
	The marking on the head covering was clear.	Pass
	The marking on the head covering was indelible.	Pass
(a)	The manufacturer's name or trademark was marked as 'unimiG', not as described in the documentation. Manufacturer to certify.	NAs
(b)	Size marking was not required as only a single size was offered.	NAp
12.1.2.2	Additional marking	
	The marking of the packaging or label was assessed as follows.	
	The marking on the packaging or label was clear.	Pass
(a)	The year of manufacture, date code or other means of traceability was marked.	Pass
(b)	No information was given that the respirator was designed to cater for a particular physical characteristic. Manufacturer to certify regarding physical characteristics.	NAs
(c)	The operational temperature range was given.	Pass
12.1.3	Particulate filters	
12.1.3.1	Marking of equipment	
	Each filter was clearly marked with the information detailed below.	
(a)	The manufacturer's name or trademark was marked as 'unimiG', not as described in the documentation. Manufacturer to certify.	NAs
(b)	The filter classification was given.	Pass
	The white colour code was present.	Pass
(c)	The filters were marked with the class, preceded by the abbreviation "PAPR"	Pass
12.1.3.2	Additional marking	
	No additional marking was provided.	NAs

**Pass** 

#### 12.2 INSTRUCTIONS FOR USE

The information supplied by the manufacturer has been assessed as detailed below, with reference only to the relevant requirements of the Standard.

INSPEC Testing Services has not assessed these instructions with respect to claims made by the manufacturer outside of the requirements of the Standard, and therefore accepts no responsibility for the legitimacy of any such claims.

#### 12.2.1 General

	Each respirator was supplied with clear instructions.	Pass
	Instructions supplied were in English.	Pass
	The supplied instructions referenced the required information as listed below.	
(a)	Limited storage life of unopened filters was given.	Pass
(b)	Limited storage life of installed filters was given.	Pass
12.2.2	Instructions for use, maintenance and storage	
	Instructions were supplied with each smallest package.	Pass
(b)	Limitations on use were defined.	Pass
(c)	Information on compatible filter types was given.	Pass
(d)	Instructions on correct assembly of parts were given.	Pass
(e)	Instructions of fitting and testing the correct facial fit were given.	Pass
(f)	Instructions for decontamination were given.	Pass
	Instructions for washing were given.	Pass
	Instructions for maintenance were given.	Pass
	Instructions for storage were given.	Pass
	Instructions for periodic testing were given.	Pass
(h)	No information on additional or operational characteristics was given.	NAp
12.2.3	Additional requirements for powered air-purifying respirators	
	The following information was supplied with each device.	Pass
(a)	A procedure for charging the battery was included.	Pass
(b)	A procedure for checking the air flow was included.	Pass
(c)	A procedure for changing the filters was included.	Pass
(d)	The range of temperatures under which the equipment was tested was given.	Pass
(d)	The humidity range under which the equipment was tested was given.	Pass
(e)	The operating range of temperatures was given.	Pass
(e)	The operating humidity range was given.	Pass

#### 12.3 ADDITIONAL MARKING

The device was a rigid or semi-rigid head covering, was not marked in accordance with AS/NZS 1801 and the required warning was given.

## **Estimates of the uncertainty of measurement**

Clause	Test	Uncertainty
2.1.1	GENERAL REQUIREMENTS - assembled respirators	See Note 1
2.1.2	Materials	See Note 1
2.1.3	Filters - mass	± 3.6g
2.1.4	Shelf life	Not applicable
2.1.5	Combined protective equipment	See applicable standard
2.1.6	Noise level	± 2.9 dB
2.1.7	Protection against explosion	See applicable standard
2.1.8	Avoidance of frictional sparks	Not applicable
2.1.9	Protection from flame impingement	See Note 1
2.2.1	FACIAL FIT - General	Not applicable
2.2.2	Assessment	± 4.7%
2.3	Breathing and connecting tube	See Note 1
3.1.1	DESIGN REQUIREMENTS - General	See Note 1
3.1.2	Exhalation valve assembly	Not applicable
3.1.3	Mouthpiece and nose clip	See Note 1
3.1.4	Nose clip	Not applicable
3.2.1	PERFORMANCE REQUIREMENTS - Facial fit	See Note 1
3.2.2	Accumulated carbon dioxide	± 4.0%
3.2.3	Positive pressure screening test	± 2.6%
3.2.4	Exhalation valve	± 2.0 ml/min
3.2.5	Exhalation resistance - Air filtering respirators	± 1.8%
3.2.6	Security of attachments	See Note 1
4.1	PARTICLE FILTERS - Design and construction	See Note 1
4.3.1	PERFORMANCE REQUIREMENTS - General	Not applicable
4.3.2	Simulated rough usage	See Note 1
4.3.5	Test of filtering efficiency	± 4.7%
4.3.6	Filters used in series	Not applicable
5.1	GAS FILTERS - Design and construction	See Note 1
5.4.1	PERFORMANCE REQUIREMENTS - General	See Note 1
5.4.2	Particulate filtration efficiency	± 4.7%
5.4.3	Simulated rough usage	See Note 1
5.4.5	Filter capacity - type A	± 4.2%
	Filter capacity - type B, chlorine	± 5.0%
	Filter capacity - type B, hydrogen sulphide	± 4.4%
	Filter capacity - type B, hydrogen cyanide	± 6.3 %

Clause	Test	Uncertainty
	Filter capacity - type E	± 5.1%
	Filter capacity - type K	± 4.3%
	Filter capacity - type AX, dimethyl ether	± 4.4%
	Filter capacity - type AX, isobutane	± 4.4%
	Filter capacity - type Hg	± 6.2%
5.4.6	Additional requirements for filters	Not applicable
5.4.7	Desorption	± 5.2%
6.1	PAPR - Design and construction	See note 1
6.3.1	Battery - flow	± 2.6%
6.3.2	Particulate filters	± 4.7%
6.3.3	Gas filters	See 5.4.5
6.3.4	Combined filters	See 6.3.2 and 6.3.3

- Note 1 The acceptance criterion for this test is a straightforward "Pass/Fail", rather than a numerical value. Consequently, as there is no value to be reported, uncertainty has not been reported either.
- Note 2 The uncertainty value is based on a standard uncertainty multiplied by a coverage factor k = 2, which provides for a confidence level of approximately 95%. Values expressed as a percentage (%) are relative.
- Note 3 It should be noted that the above values have not been taken into account when making assessment to the pass/fail criteria.

INSPEC Test Report No: 1.15.09.65 Page 20 of 20

# **ANNEX**

This Annex comprises one section.

1. Photographs of the product tested.

(1 page)

## Welding Guns of Australia Pty Ltd's model P1004

